

ROCK RIPRAP SPECIFICATIONS AND BEDDING

IDOT GRADATION	MAXIMUM ROCK SIZE (lb)*	EQUIVALENT DIAMETER (SPHERICAL)(in)*	MINIMUM BEDDING THICKNESS (in)	MINIMUM THICKNESS (in)
RR-3	50	10	-	8
RR-4	150	15	6	16
RR-5	400	21	8	22
RR-6	600	24	10	26
RR-7	1000	28	12	30

NOTES:

- RIPRAP SHALL CONFORM TO SECT. 281 OF THE STANDARD SPECIFICATIONS.
- INSTALL FILTER FABRIC UNDER ALL RIPRAP AND BEDDING. FILTER FABRIC SHALL CONFORM TO SECT. 282 OF THE STANDARD SPECIFICATIONS.

*ASSUMES A MINIMUM SPECIFIC GRAVITY OF 2.450 AND A MINIMUM UNIT WEIGHT OF 153 lb/cf

ROCK RIPRAP SIZE REQUIREMENTS AND THICKNESS

CULVERT DIAMETER (in)	MINIMUM TAILWATER				MAXIMUM TAILWATER			
	MAX CONDUIT VELOCITY = 5 fps		MAX CONDUIT VELOCITY = 10 fps		MAX CONDUIT VELOCITY = 5 fps		MAX CONDUIT VELOCITY = 10 fps	
	IDOT GRADATION	APRON LENGTH (ft)	IDOT GRADATION	APRON LENGTH (ft)	IDOT GRADATION	APRON LENGTH (ft)	IDOT GRADATION	APRON LENGTH (ft)
12	RR-3	10	RR-3	12	RR-3	12	RR-3	15
18	RR-3	14	RR-4	16	RR-3	12	RR-3	16
24	RR-3	16	RR-4	20	RR-3	14	RR-4	17
30	RR-3	18	RR-4	22	RR-3	16	RR-4	20
36	RR-4	20	RR-5	24	RR-3	16	RR-4	22
48	RR-4	24	RR-6	28	RR-4	20	RR-4	24
60	RR-5	32	RR-6	36	RR-4	22	RR-5	26
72	RR-6	40	RR-6	44	RR-5	24	RR-5	29
96	RR-7	50	RR-7	54	RR-5	26	RR-5	32

NOTES:

- IF TAILWATER DEPTH FROM THE PIPE INVERT IS LESS THAN HALF THE DIAMETER OF THE PIPE, THEN MINIMUM TAILWATER CONDITIONS EXIST.
- ADAPTED FROM THE ILLINOIS URBAN MANUAL

Revised:

-
-
-
-

Drawing Name

RIPRAP DETAILS

Drawing Number

UD-02e

Date: 08/27/2015

Drawn	Checked
DD	AW



City of

Crystal Lake
 ILLINOIS