



PCC: USE PCC OR BAM
 BAM: USE BAM
 GRAVEL: USE CA-6 CRUSHED

CA-7 WASHED STONE SHALL
 BE BACKFILLED FROM
 MINIMUM 4" BELOW THE PIPE
 TO THE SPRING LINE OF PIPE

TRENCH BACK FILL MATERIAL (TBF)
 TO BE PLACED IN 6" COMPACTED
 LAYERS. USE CA-6 GRADE 8 OR 9
 AGGREGATE. COMPACT TO 90% OF
 MODIFIED PROCTOR.

LEGEND:

- 1 TEMPORARY STREET PATCHES DURING WINTER CONSTRUCTION SHALL BE 4" P.C. CONCRETE, IDOT CLASS SI OR A MIN. 3" OF UPM (COLD PATCH). PERMANENT PATCHES SHALL BE COMPLETED AS SOON AS POSSIBLE IN THE SPRING.
- 2 HMA BASE COURSE MUST BE AUTHORIZED BY THE CITY ENGINEER.
- 3 FOR CERTAIN UTILITY STREET CUTS, THE CITY ENGINEER MAY AUTHORIZE OR REQUIRE THE USE OF A CONTROLLED LOW-STRENGTH MATERIAL (CLSM) AS PER THE IDOT SPECIAL PROVISIONS.

Revised:
1. 06/12/2015
2. 9/8/2021 KL - CA-7 TO SPRING LINE OF PIPE
3.
4.

Drawing Name

PAVEMENT CUT AND REPLACEMENT

Drawing Number	RD-06
Date:	05/19/2015
Drawn	Checked
JH	AW

