



- NOTES:**
1. MONITORING MANHOLES: MUST BE LOCATED ON USER'S PREMISES UNLESS OTHERWISE DIRECTED BY THE CITY.
 2. USE DROP CONNECTIONS FOR ANY SANITARY SEWER.
 3. PIPE ENTERING TWO (2) FEET OR MORE ABOVE THE LOWEST PIPE INVERT. SEE STANDARD INSIDE DROP MANHOLE DETAIL US-05.
 4. ALL MANHOLES MUST BE DAMP PROOF PER IDOT SPECIFICATIONS 1060 "WATER PROOFING MATERIALS."
 5. SERVICE LINE INVERT ELEVATION SHALL BE AT SPRING LINE OR CROWN OF MAIN LINE SEWER.
 6. CHIMNEY SEAL REQUIRED - SEE DETAIL US-06.
 7. IF STRUCTURE IS TO BE MAINTAINED BY THE CITY, ALL STEPS SHALL BE REMOVED PRIOR TO CITY ACCEPTANCE.

Revised:
1. 06/12/2015
2. 08/21/2018
3. JRG NOTE 7. 8-18-2023
4.

Drawing Name

STANDARD SANITARY AND MONITORING MANHOLE

Drawing Number	US-04
Date:	06/12/2015
Drawn	Checked
JH	VR

